



Uisce Éireann
Bosca OP 448
Oifig Sheachadta na
Cathrach Theas
Cathair Chorcaí

Irish Water
PO Box 448,
South City
Delivery Office,
Cork City.

www.water.ie

Cormac Dooley
MCD Civil
Stanhope St
Athy
Co. Kildare
R14HT25

23 March 2020

Dear Cormac Dooley,

**Re: Connection Reference No CDS20002012 pre-connection enquiry -
Subject to contract | Contract denied**

Connection for Housing Development of 3 unit(s) at Craddockstown, Naas, Co. Kildare

Irish Water has reviewed your pre-connection enquiry in relation to a water and wastewater connection at Craddockstown, Naas, Co. Kildare.

Based upon the details that you have provided with your pre-connection enquiry and on the capacity currently available in the network(s), as assessed by Irish Water, we wish to advise you that, subject to a valid connection agreement being put in place, your proposed connection to the Irish Water network(s) can be facilitated.

Water:

New connection to the existing network is feasible without upgrade.

This Confirmation of Feasibility to connect to the Irish Water infrastructure also does not extend to your fire flow requirements. Please note that Irish Water cannot guarantee a flow rate to meet fire flow requirements and in order to guarantee a flow to meet the Fire Authority requirements, you may need to provide adequate fire storage capacity within your development.

In order to determine the potential flow that could be delivered during normal operational conditions, an onsite assessment of the existing network is required.

Wastewater:

New connection to the existing network is feasible without upgrade.

The proposed wastewater connection for this development connects to the Irish Water network via infrastructure that has not been taken in charge by Irish Water (Third Party Infrastructure). Please be advised that at connection application stage and prior to the commencement of any Self-Lay Works, you have to:

- identify and procure transfer to Irish Water of the arterial wastewater Infrastructure within the Third Party Infrastructure;
- demonstrate that the arterial infrastructure are in compliance with requirements of Irish Water Code of Practice and Standard Details and in adequate condition and capacity to cater for additional load from the Development.

All infrastructure should be designed and installed in accordance with the Irish Water Codes of Practice and Standard Details. A design proposal for the water and/or wastewater infrastructure should be submitted to Irish Water for assessment. Prior to submitting your planning application, you are required to submit these detailed design proposals to Irish Water for review.

You are advised that this correspondence does not constitute an offer in whole or in part to provide a connection to any Irish Water infrastructure and is provided subject to a connection agreement being signed at a later date.

A connection agreement can be applied for by completing the connection application form available at **www.water.ie/connections**. Irish Water's current charges for water and wastewater connections are set out in the Water Charges Plan as approved by the Commission for Regulation of Utilities.

If you have any further questions, please contact Deirdre Ryan from the design team on 022 54620 or email deiryan@water.ie. For further information, visit www.water.ie/connections.

Yours sincerely,



Maria O'Dwyer

Connections and Developer Services