

Kate Finnegan

Block S,  
Eastpoint Business Park,  
Alfie Byrne Road,  
Dublin 3,  
D03H3F4

**Uisce Éireann**  
Bosca OP 448  
Oifig Sheachadta na  
Cathrach Theas  
Cathair Chorcaí

**Irish Water**  
PO Box 448,  
South City  
Delivery Office,  
Cork City.

[www.water.ie](http://www.water.ie)

14 April 2022

**Re: CDS22002582 pre-connection enquiry - Subject to contract | Contract denied**

**Connection for Business Connection of 1 unit(s) at The Village Centre, Main Street, Kildare**

Dear Sir/Madam,


Irish Water has reviewed your pre-connection enquiry in relation to a Water & Wastewater connection at The Village Centre, Main Street, Kildare (the **Premises**). Based upon the details you have provided with your pre-connection enquiry and on our desk top analysis of the capacity currently available in the Irish Water networks as assessed by Irish Water, we wish to advise you that your proposed connection to the Irish Water networks can be facilitated at this moment in time.

SERVICE	<b>OUTCOME OF PRE-CONNECTION ENQUIRY</b> <b><u>THIS IS NOT A CONNECTION OFFER. YOU MUST APPLY FOR A CONNECTION(S) TO THE IRISH WATER NETWORK(S) IF YOU WISH TO PROCEED.</u></b>
Water Connection	Feasible without infrastructure upgrade by Irish Water
Wastewater Connection	Feasible without infrastructure upgrade by Irish Water
<b>SITE SPECIFIC COMMENTS</b>	
The design and construction of the Water & Wastewater pipes and related infrastructure to be installed in this development shall comply with the Irish Water Connections and Developer Services Standard Details and Codes of Practice that are available on the Irish Water website. Irish Water reserves the right to supplement these requirements with Codes of Practice and these will be issued with the connection agreement.	

**Uisce Éireann**  
 Bosca OP 448  
 Ríofa Sheachadta na  
 Cathrach Theas  
 Cathair Chorcaí

**ish Water**  
 O Box 448,  
 outh City  
 elivery Office,  
 ork City.

[www.water.ie](http://www.water.ie)



[www.water.ie](http://www.water.ie)

[www.water.ie](http://www.water.ie)


[www.water.ie](http://www.water.ie)

- [www.water.ie](http://www.water.ie)

- 5) A Connection Agreement cannot be issued until all statutory approvals are successfully in place.
- 6) Irish Water Connection Policy/ Charges can be found at <https://www.water.ie/connections/information/connection-charges/>
- 7) Please note the Confirmation of Feasibility does not extend to your fire flow requirements.
- 8) Irish Water is not responsible for the management or disposal of storm water or ground waters. You are advised to contact the relevant Local Authority to discuss the management or disposal of proposed storm water or ground water discharges
- 9) To access Irish Water Maps email [datarequests@water.ie](mailto:datarequests@water.ie)
- 10) All works to the Irish Water infrastructure, including works in the Public Space, shall have to be carried out by Irish Water.

If you have any further questions, please contact Tinus van der Walt from the design team at [twalt@water.ie](mailto:twalt@water.ie) For further information, visit **[www.water.ie/connections](http://www.water.ie/connections)**.

Yours sincerely,



**Yvonne Harris**

**Head of Customer Operations**