

Figure 1 - Layout Plan proposed new Bus Shelter/Boarding platform



Figure 2 - Bus shelter example





Figure 2 - General Arrangement layout



Key Plan - Street Map

Notes: 1. No dimensions to be scaled from this drawing. 2. All sizes to be checked on site and any discrepancies to be reported to the engineer. Key: New footway / hardstanding construction (concrete) 35.2m² Proposed planting R.G Existing Gully — Existing road markings Proposed 9m Accessible kerbing (Kassell) - 160mm max. height Include 150mm wide weather/slip resistant paint or resin in a contrasting colour to the hardstanding to asssit the visually impaired Proposed 1m Transition Kerb - 100mm upstand to 160mm Proposed Crossing kerb - 6mm upstand Proposed HB2 Kerbing - 125mm upstand Proposed concrete block paving (200 x 100 x 50mm). laid 100mm deep to the rear of crossing kerbs. Blocks to be painted with a weather/slip resistant paint or resin, in a contrasting colour to the hardstanding. Existing bus stop poles to be removed (Coords: 53.22742,-6.64733) L.C
Existing lighting column Existing sign — — — Setting out reference point Proposed Bus Stop cage - RPM 030 - 1.0m mark,1.0m gap,
100mm wide - 1.6m text (24m long cage required) Existing Service covers New Micro Pillar. Direction of connection route to nearest ESB Pole or mini-pillar to be agreed with ESB prior to commencement of works onsite. Buff Tactile Blister Paving (400 x 400mm) Desired gradient 1:20. Dropped kerb with max. upstand of 6mm/or flush. Reinstate carraigeway as result of any new kerb works Proposed Bus Shelter (5.2m x 1.85m) Litter Bin relocation point **Electrical Supply Requirements.** Power supply to the shelter must be from the nearest single phase ESB Networks suppy point. Only ESB approved ducting may be used: 63mm outside diameter for duct runs no longer than 12m and 110mm outside diameter for duct runs longer than 12m.

The duct must be located 600m below the final pavement level. Please note ESB yellow marker tape must be installed at 300mm below finished ground level, over the electrical duct. The tape must be wider than the electrical service. Aditionally where the electrical duct is installed in the carraigeways and grassed areas ESB red marker strip is to be used at a mnimum distance of 75mm above the duct, and is to be wider than the electrical service.

A suitable draw rope for installation of supply cable must be left in place in the duct to facilitate later cable installation.

D.

No part of the public lighting network can be used in supplying the shelter and the shelter cannot be connected to a public lighting mini-pillar.

Bus Shelter construction.

Please refer to JC Decaux design details for the shelter structure, including foundaion and structure design

NOTES:

- 1. ALL DIMENSIONS ARE IN METRES UNLESS OTHERWISE STATED. 2. LOCATIONS ARE APPROXIMATE AND ARE TO BE AGREED ON SITE WITH
- THE OVERSEEING ORGANISATION.
- 3. ALL UTILITIES SHOWN ARE INDICATIVE ONLY AND REMAIN THE RESPONSIBILITY OF THE CONTRACTOR.
- 4. NO TOPOGRAPHIC SURVEY WAS CARRIED OUT PRIOR TO THE DESIGN SHOWN ON THIS DRAWING. 5 SITE CONDITIONS TO BE CHECKED BY THE CONTRACTOR BEFORE
- PROCEEDING TO ANY TASK. 7. INDICATIVE ROAD MARKINGS HAVE BEEN PREPARED BASED ON AERIAL IMAGERY. ROAD MARKING LAYOUT TO BE CHECKED BY CONTRACTOR

2			
1			
No.	Date	Issue / Revision	Chkd.

Project: NTA & KCC Bus Shelter Programme.

> Proposed Installation of new Bus Shelter at SB stop 103801 Roseville, Naas (Dublin Rd)

Dwg. Title:

Roseville, Naas (Dublin Rd) Bus Stop 103801 General Arangement

Dwg. No. 6		Rev.	Stage:		
			PART VIII		
Date: 17/07/2023	Scale: NTS		TENDER		
Drawn: P.K	Approved: D.McC		CONTRACT		
Transport, Mobility & Open Spaces					



DRAFT CONCEPT DESIGN - FOR COMMENT

A/Director of Services - Celina Barrett Senior Engineer - Donal Hodgins, BA, BAI, MIEI, C.Eng Aildare County Council, Comhairle Chontae Cill Dara Áras Chill Dara, Devoy Park, Naas, Co.Kildare T:+353-45-980424 F:+353-45-980420 E: roads@kildarecoco.ie