



LEGEND:

EXISTING WATERMAIN.....	EXST_WM
EXISTING WATERMAIN ABANDONED.....	EXST_WM
EXISTING 6m WAYLEAVE.....	EXST_WM
EXISTING BOUNDARY.....	WM
PROPOSED WATERMAIN.....	WM
PROPOSED SLUICE VALVE.....	SV
PROPOSED SCOUR VALVE.....	SCV
PROPOSED AIR VALVE.....	AV
PROPOSED BULK WATER METER.....	BM
PROPOSED WATER HYDRANT.....	HD



This drawing has been prepared for the use of AECOM's client. It may not be used, modified, reproduced or relied upon by third parties, except as agreed by AECOM or as required by law. AECOM accepts no responsibility, and denies any liability, whatsoever, to any party that uses or relies on this drawing without AECOM's express written consent. All measurements must be obtained from the stated dimensions.

AECOM
PROJECT
PART 8 PROPOSED REDEVELOPMENT OF THE WONDERFUL BARN P82024.10
CELBRIDGE RD, BARNHALL, LEIXLIP, CO. KILDARE
CLIENT

KILDARE COUNTY COUNCIL
CONSULTANT
AECOM
Adelphi Plaza
George's Street Upper
Dun Laoghaire Co.Dublin
+353 (0) 1 696 6200 tel
www.aecom.com

- NOTES**
- THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT ARCHITECTURAL AND ENGINEERING DRAWINGS. ANY DISCREPANCIES, ERRORS OR OMISSIONS TO BE BROUGHT TO THE ATTENTION OF THE DESIGNER.
 - ALL DIMENSIONS TO BE CHECKED BY THE CONTRACTOR ON SITE PRIOR TO COMMENCEMENT OF WORKS.
 - AECOM LIMITED TO BE INFORMED BY THE CONTRACTOR OF ANY DISCREPANCIES PRIOR TO THE COMMENCEMENT OF WORKS ON SITE.
 - DIMENSIONS OF ALL BOUNDARIES AND ADJOINING ROADS TO BE CHECKED ON SITE PRIOR TO COMMENCEMENT OF WORKS.
 - DO NOT SCALE. ALL MEASUREMENTS AND COORDINATES TO BE CHECKED ON SITE.
 - THE DEVELOPMENT SHALL HAVE A BULK WATER METER (EXACT LOCATION TO BE AGREED WITH IRISH WATER) IN ACCORDANCE WITH IRISH WATER CODE OF PRACTICE SECTION 3.15.4.
 - EACH HOUSE UNIT SHALL HAVE AN APPROVAL BOUNDARY BOX (REFER TO APPENDIX A OF THE IRISH WATER CODE OF PRACTICE FOR WATER INFRASTRUCTURE) WITH INTEGRAL STOPCOCK AND SUITABLE FOR THE RECEPTION OF A WATER METER (REFER TO IRISH WATER CODE OF PRACTICE FOR WATER INFRASTRUCTURE SECTION 3.14).
 - ALL PROPERTIES SHALL HAVE METERS INSTALLED INTERNALLY WITHIN THE PREMISES IN ACCORDANCE WITH THE BUILDING CONTROL AUTHORITY'S REQUIREMENTS AND SUBJECT TO REVIEW BY IRISH WATER AS PER IRISH WATER CODE OF PRACTICE FOR WATER INFRASTRUCTURE SECTION 3.15.2.
 - ALL PROPOSED WATERMAIN PIPEWORK TO BE HDPE WITH MINIMUM PE80 RATING IN ACCORDANCE WITH IRISH WATER CODE OF PRACTICE FOR WATER INFRASTRUCTURE.
 - THE MINIMUM PIPE DIAMETER PROPOSED IS 100mm.
 - ALL WATERMANS WILL HAVE A MINIMUM COVER OF 900mm. ALL SERVICE PIPES CONNECTING PROPERTIES WILL HAVE MINIMUM COVER OF 750mm.
 - HYDRANTS SHALL BE DOUBLE FLANGED DRILLED TO PN16 AND SHALL COMPLY WITH BS EN 14339, IS EN 1074 PART 6 AND 135 750. REFER TO IRISH WATER CODE OF PRACTICE FOR WATER INFRASTRUCTURE SECTION 3.16.5.
 - SLUICE VALVES HAVE BEEN PROVIDED SO THAT INDIVIDUAL SECTIONS CAN BE ISOLATED & WILL COMPLY TO BS 5163. THE DEPTH OF THE SLUICE VALVE SPINDLE CAP BELOW FINISHED GROUND WILL NOT EXCEED 300mm.
 - ALL WATERMAIN DETAILS TO BE IN ACCORDANCE WITH THE IRISH WATER INFRASTRUCTURE STANDARD DETAILS AND CODE OF PRACTICE FOR WATER INFRASTRUCTURE.
 - PROPOSED COMMERCIAL UNITS TO BE SERVED BY A PRIVATE SERVICE CONNECTION AND BULK FLOW METER IN ACCORDANCE WITH STD-W-26 AND SECTION 3.15.3 OF THE IRISH WATER CODE OF PRACTICE.

ISSUE/REVISION		
0	05.06.2024	ISSUED FOR PART 8
I/R	DATE	DESCRIPTION

PROJECT NUMBER
60689541
SHEET TITLE
PROPOSED WATERMAIN LAYOUT

SHEET NUMBER
60689541-ACM-XX-00-DR-CE-10-2701

A **PROPOSED WATERMAIN LAYOUT**
2701 Scale: 1:500

ORDNANCE SURVEY IRELAND LICENCE NO CYAL50217544
ORDNANCE SURVEY IRELAND / GOVERNMENT OF IRELAND